

Compliance Document

No. D 075386 0137 Rev. 02

Holder of Certificate: **Shenzhen Kstar New Energy Company Limited**
The 9th Floor, R&D Building
Kstar Industrial Park, Guangming Hi-tech Industrial Zone
518107 Shenzhen, Guangdong Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Converter**
(PV grid-interactive inverter)

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290213000403

Date, 2021-09-23



(Billy Qiu)

Compliance Document

No. D 075386 0137 Rev. 02

Model(s):

**BluE-G 3000S, BluE-G 3000S-M1,
 BluE-G 3000D, BluE-G 3000D-M0, BluE-G 3000D-M1,
 BluE-G 3600D, BluE-G 3600D-M0, BluE-G 3600D-M1,
 BluE-G 4000D, BluE-G 4000D-M0, BluE-G 4000D-M1,
 BluE-G 4200D, BluE-G 4200D-M0, BluE-G 4200D-M1,
 BluE-G 4600D, BluE-G 4600D-M1**

Parameters:

Model Specifications	BluE-G 3000S	BluE-G 3000D	BluE-G 3600D	BluE-G 4000D	BluE-G 4200D	BluE-G 4600D
Input(DC)						
Max. DC voltage	600Vd.c.					
Normal DC voltage	380Vd.c.					
MPPT voltage range	80V-550Vd.c.					
Number of MPP trackers	1	2	2	2	2	2
Strings per MPP tracker	1	1	1	1	1	1
Max. input current per MPPT tracker	12.5 Ad.c.	11 Ad.c.*2	11 Ad.c.*2	11 Ad.c.*2	11 Ad.c.*2	12.5 Ad.c.*2
PV short circuit current	15.6 Ad.c.	13.2 Ad.c. *2	13.2 Ad.c. *2	13.2 Ad.c. *2	13.2 Ad.c. *2	15.6 Ad.c. *2
Output (AC)						
Normal AC output Power	3000W	3000W	3600W	4000W	4200W	4600W
Max. AC output Power	3300W	3300W	3960W	4400W	4600W	4600W
Max. AC apparent Power	3300VA	3300VA	3960VA	4400VA	4600VA	4600VA
Normal AC voltage	230Va.c.					
Normal AC grid frequency	50 Hz					
Max. output current	14.5 Aa.c.	14.5 Aa.c.	17.3 Aa.c.	19 Aa.c.	20 Aa.c.	20 Aa.c.

Compliance Document

No. D 075386 0137 Rev. 02

Model Specifications	BluE-G 3000S-M1	BluE-G 3000D-M0	BluE-G 3000D-M1	BluE-G 3600D-M0	BluE-G 3600D-M1	BluE-G 4000D-M0	BluE-G 4000D-M1
Input(DC)							
Max. DC voltage	600Vd.c.						
Normal DC voltage	380Vd.c.						
MPPT voltage range	80V-560Vd.c.						
Number of MPP trackers	1	2	2	2	2	2	2
Strings per MPP tracker	1	1	1	1	1	1	1
Max. input current per MPPT tracker	15 Ad.c.	13 Ad.c.*2	15 Ad.c.*2	13 Ad.c.*2	15 Ad.c.*2	13 Ad.c.*2	15 Ad.c.*2
PV short circuit current	18 Ad.c.	15.6 Ad.c.*2	18 Ad.c.*2	15.6 Ad.c.*2	18 Ad.c.*2	15.6 Ad.c.*2	18 Ad.c.*2
Output (AC)							
Normal AC output Power	3000W	3000W	3000W	3600W	3600W	4000W	4000W
Max. AC output Power	3300W	3300W	3300W	3960W	3960W	4400W	4400W
Max. AC apparent Power	3300VA	3300VA	3300VA	3960VA	3960VA	4400VA	4400VA
Normal AC voltage	230Va.c.						
Normal AC grid frequency	50 Hz						
Max. output current	14.5 Aa.c.	14.5 Aa.c.	14.5 Aa.c.	17.3 Aa.c.	17.3 Aa.c.	19 Aa.c.	19 Aa.c.

Compliance Document

No. D 075386 0137 Rev. 02

Model Specifications	BluE-G 4200D-M0	BluE-G 4200D-M1	BluE-G 4600D-M1
Input(DC)			
Max. DC voltage	600Vd.c.		
Normal DC voltage	380Vd.c.		
MPPT voltage range	80V-560Vd.c.		
Number of MPP trackers	1	2	2
Strings per MPP tracker	1	1	1
Max. input current per MPPT tracker	13 Ad.c.*2	15 Ad.c.*2	15 Ad.c.*2
PV short circuit current	15.6 Ad.c. *2	18 Ad.c. *2	18 Ad.c. *2
Output (AC)			
Normal AC output Power	4200W	4200W	4600W
Max. AC output Power	4600W	4600W	4600W
Max. AC apparent Power	4600VA	4600VA	4600VA
Normal AC voltage	230Va.c.		
Normal AC grid frequency	50 Hz		
Max. output current	20 Aa.c.	20 Aa.c.	20 Aa.c.

Tested according to:

NRS 097-2-1:2017 Edition 2.1