

Compliance Document

No. D 075386 0228 Rev. 00

Holder of Certificate: **Shenzhen Kstar New Energy Company Limited**
The 9th Floor, R&D Building
Kstar Industrial Park, Guangming Hi-tech Industrial Zone
518107 Shenzhen, Guangdong Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Converter
(Hybrid Inverter)**

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290233080601

Date, 2023-09-01



(Billy Qiu)

Compliance Document

No. D 075386 0228 Rev. 00

Model(s): KAC50DP

Parameters:

PV input parameter	
Maximum input voltage	1000 Vd.c.
MPPT voltage range	350~800 Vd.c.
MPPT voltage range (full load)	667~750 Vd.c.
Maximum input current	3*36 Ad.c.
PV I _{SC}	3*40 Ad.c.
Maximum input power	75000 W
Battery input/output parameter	
Battery type	Lithium-ion
Input voltage range	350~750 Vd.c.
Rated voltage	512 Vd.c.
Maximum input/output voltage	750 Vd.c.
Maximum charging current	2*55 Ad.c.
Maximum charging power	55000 W
Maximum discharging current	2*55 Ad.c.
Maximum discharging power	55000 W
Grid parameter	
Rated input/output voltage	230/400 Va.c., 3/N/PE
Rated input/output frequency	50 Hz
Maximum input current	80 Aa.c.
Maximum input active power	50000 W
Maximum input apparent power	55000 VA
Rated output current	72 Aa.c.
Maximum continuous output current	80 Aa.c.
Rated output active power	50000 W
Maximum output active power	50000 W
Maximum output apparent power	55000 VA
Power factor	0.9 inductive(under-excited) to 0.9 capacitive(over-excited)

**Tested
according to:**

NRS 097-2-1:2017 Edition 2.1